



## Fort Erie Distribution System

### Summary Report for June 2023

#### Chlorine (free)

# samples:	198	min:	0.38	mg/L
# detects:	198	max:	1.49	mg/L
# non-detects:	0	avg:	0.88	mg/L (based on 198 numerical results)
# exceedances:	0			

#### Escherichia coli / E. coli (counts)

# samples:	51	min:	0	counts/100ml
# detects:	51	max:	0	counts/100ml
# non-detects:	0	Geometric Mean:	0	counts/100ml (based on 51 numerical results)
# exceedances:	0			

#### Total coliforms (counts)

# samples:	51	min:	0	counts/100ml
# detects:	51	max:	4	counts/100ml
# non-detects:	0	Geometric Mean:	1	counts/100ml (based on 51 numerical results)
# exceedances:	2			

#### Heterotrophic Plate Count / HPC

# samples:	51	min:	0	CFU/ml
# detects:	51	max:	7	CFU/ml
# non-detects:	0	Geometric Mean:	1	CFU/ml (based on 51 numerical results)
# exceedances:	0			

#### Haloacetic acids 5 / HAA5

# samples:	3	min:	0.0078	mg/L
# detects:	3	max:	0.0167	mg/L
# non-detects:	0	avg:	0.0117	mg/L (based on 2 numerical results)
# exceedances:	0			

#### Total Trihalomethanes / TTHM

# samples:	3	min:	0.0326	mg/L
# detects:	3	max:	0.0485	mg/L
# non-detects:	0	avg:	0.0382	mg/L (based on 3 numerical results)
# exceedances:	0			

P=present, A=absent, PR=presumptive, ND=non-detect, U=non-detect, OR=over-range, OG=overgrown,  
 TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment  
 cfu= colony forming units

< means less than lower detection limit shown  
 > means greater than upper detection limit shown  
 « means detected & less than number shown  
 » means detected & greater than number shown  
 \* Indicates Criteria is exceeded