



Fort Erie Distribution System

Summary Report for June 2026

Chlorine (free)

# samples:	166	min:	0.33	mg/L
# detects:	166	max:	1.15	mg/L
# non-detects:	0	avg:	0.73	mg/L (based on 166 numerical results)
# exceedances:	0			

Escherichia coli / E. coli (counts)

# samples:	55	min:	0	counts/100ml
# detects:	55	max:	0	counts/100ml
# non-detects:	0	Geometric Mean:	0	counts/100ml (based on 55 numerical results)
# exceedances:	0			

Total coliforms (counts)

# samples:	55	min:	0	counts/100ml
# detects:	55	max:	0	counts/100ml
# non-detects:	0	Geometric Mean:	0	counts/100ml (based on 55 numerical results)
# exceedances:	0			

Heterotrophic Plate Count / HPC

# samples:	55	min:	0	CFU/ml
# detects:	55	max:	5	CFU/ml
# non-detects:	0	Geometric Mean:	1	CFU/ml (based on 55 numerical results)
# exceedances:	0			

Total Trihalomethanes / TTHM

# samples:	3	min:	0.037	mg/L
# detects:	3	max:	0.042	mg/L
# non-detects:	0	avg:	0.039	mg/L (based on 3 numerical results)
# exceedances:	0			

Haloacetic acids 5 / HAA5

# samples:	3	min:	0.0105	mg/L
# detects:	3	max:	0.0271	mg/L
# non-detects:	0	avg:	0.0174	mg/L (based on 3 numerical results)
# exceedances:	0			

P=present, A=absent, PR=presumptive, ND=non-detect, U=non-detect, OR=over-range, OG=overgrown,
 TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment
 cfu= colony forming units

< means less than lower detection limit shown
 > means greater than upper detection limit shown
 « means detected & less than number shown
 » means detected & greater than number shown

* Indicates Criteria is exceeded