



## Fort Erie Distribution System

### Summary Report for December 2022

#### Chlorine (free)

# samples:	133	min:	0.31	mg/L
# detects:	133	max:	1.84	mg/L
# non-detects:	0	avg:	0.85	mg/L (based on 133 numerical results)
# exceedances:	0			

#### Escherichia coli / E. coli (counts)

# samples:	47	min:	0	counts/100ml
# detects:	47	max:	0	counts/100ml
# non-detects:	0	Geometric Mean:	0	counts/100ml (based on 47 numerical results)
# exceedances:	0			

#### Total coliforms (counts)

# samples:	47	min:	0	counts/100ml
# detects:	47	max:	0	counts/100ml
# non-detects:	0	Geometric Mean:	0	counts/100ml (based on 47 numerical results)
# exceedances:	0			

#### Heterotrophic Plate Count / HPC

# samples:	47	min:	0	CFU/ml
# detects:	47	max:	45	CFU/ml
# non-detects:	0	Geometric Mean:	1	CFU/ml (based on 47 numerical results)
# exceedances:	0			

#### Haloacetic acids 5 / HAA5

# samples:	3	min:	0.0049	mg/L
# detects:	3	max:	0.0142	mg/L
# non-detects:	0	avg:	0.0106	mg/L (based on 3 numerical results)
# exceedances:	0			

#### Total Trihalomethanes / TTHM

# samples:	3	min:	0.0219	mg/L
# detects:	3	max:	0.0235	mg/L
# non-detects:	0	avg:	0.0229	mg/L (based on 3 numerical results)
# exceedances:	0			

P=present, A=absent, PR=presumptive, ND=non-detect, U=non-detect, OR=over-range, OG=overgrown,

TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

cfu= colony forming units

< means less than lower detection limit shown

> means greater than upper detection limit shown

« means detected & less than number shown

» means detected & greater than number shown

\* Indicates Criteria is exceeded