

Fort Erie Distribution System

Summary Report for September 2022

Chlorine (free)

# samples:	244	min:	0.00	mg/L
# detects:	244	max:	1.37	mg/L

non-detects: 0 avg: 0.80 mg/L (based on 243 numerical results)

exceedances: 1

Escherichia coli / E. coli (counts)

# samples:	44	min:	0	counts/100ml
# detects:	44	max:	0	counts/100ml

non-detects: 0 Geometric Mean: 0 counts/100ml (based on 44 numerical results)

exceedances: 0

Total coliforms (counts)

# samples:	44	min:	0	counts/100ml
# detects:	44	max:	0	counts/100ml

non-detects: 0 Geometric Mean: 0 counts/100ml (based on 44 numerical results)

exceedances: 0

Heterotrophic Plate Count / HPC

# samples:	44	min:	0	CFU/ml
# detects:	44	max:	12	CFU/ml

non-detects: 0 Geometric Mean: 1 CFU/ml (based on 44 numerical results)

exceedances: 0

Haloacetic acids 5 / HAA5

# samples:	3	min:	0.0142	mg/L
# detects:	3	max:	0.0895	mg/L

non-detects: 0 avg: 0.0530 mg/L (based on 3 numerical results)

exceedances: 0

Total Trihalomethanes / TTHM

# samples:	3	min:	0.0333	mg/L	
# detects:	3	max:	0.0449	mg/L	
# non-detects:	0	avg:	0.0397	mg/L (based on 3 numerical results)	
# exceedances:	0				

P=present, A=absent, PR=presumptive, ND=non-detect, U=non-detect, OR=over-range, OG=overgrown, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment cfu= colony forming units

< means less than lower detection limit shown</p>

> means greater than upper detection limit shown

[«] means detected & less than number shown

[»] means detected & greater than number shown

^{*} Indicates Criteria is exceeded